G-5301 WFGD Spec Outstanding Issues

Project No.	12681-006	
	9/8/11	

Item	Issue	Section	Remarks
1	NPPD to provide contact info for Karla Tremel and Bob Nitsch	Section B, paragraph E	Karla J. Tremel, Procurement Manager ph: 402-563-5457, fax: 402-563-5034, email: kjtreme@nppd.com, Bob B. Nitsch - Project Engineering Leader, ph: 308-386-5312, fax: 308-386-5275, email: bbnitsc@nppd.com
2	NPPD to confirm number of days to accept retainage payment after final invoicing	Section C, paragraph C	NPPD requests that S&L draft a progress payment schedule for the FGD and it would replace the current payment language in Section D. The final payment should not exceed 10%, and would be due 30 days after all terms of the Contract, except warranty, have been fulfilled.
3	NPPD to insert pre-bid paragraph from the A-2 page	Section C, paragraph F	See the A-2 page to be provided separately
4	NPPD to provide expected award date	Section C, paragraph I	At time of issuing contract
5	Need to determine substantial and final completion dates	Section C, paragraph T, X	At time of issuing contract
6	Determine appropriate LD values for late documentation and completion dates. Values currently in document are typical values.	Section C, paragraph X	Question to S&L: What are these values based on? Since penalties are not legal in Nebraska, these values need to be a percentage (not to exceed) of what the actual damages are expected to be for not meeting the milestone dates. Who can determine / estimate what NPPD's actual damages would be?
7	Determine LD values for performance guarantees.	Section C, paragraph X.5	See item 6
8	NPPD to advise how many hardcopies of final as-built drawings	Section C, paragraphs W.3.b and W.7.b	Three hard copies plus electronic
9	NPPD to advise the personnel who should be notified of shipments	Section F, paragraph NN.2	At time of issuing contract
10	NPPD to advise the personnel who should be notified of deliveries	Section F, paragraph NN.5	At time of issuing contract
11	Any of the FGD buildings to have office space, or control stations / electrical rooms? This impacts HVAC and fire protection requirements.	Section G	
12	Need to determine schedule	Section G, Section 013216	At time of issuing contract
13	NPPD to confirm number of hard copies desired for draft version and final version of training manual	Section G, Section 017900	At time of issuing contract
14	NPPD to determine # of training manuals required	Section G, Section 017900	At time of issuing contract
15	NPPD to provide existing fire protection system information - fire pump curves, location of fire pumps, fire pump discharge piping layout, existing underground fire loop layout, existing main fire alarm control panel location, manufacturer, spare terminal space, etc. S&L will also review previously received drawings and data.	Section G, Section 210000 Attachment 5	
16	NPPD to confirm what type of fire hose station is preferred - Class II or Class III	Section G, Section 210000	
17	Booster fire pump is likely not required, however, this is based on existing fire system and available supply pressure. For now, spec will include requirements for a booster pump and associated jockey pump	Section G, Section 210000	

NPPD to advise contact info for drawings and manuals

31 Due dates for many of the drawing types still to be determined

18	Interfacing of the new fire systems to the existing fire system main control panel is unclear. Details of existing fire alarm/control system are required and need to determine how and who will perform the interface work. This will apply to other contractors as well.	Section G, Section 210000	
19	, ,	Section G, Section 441130 Section C	
20	, , ,	Section G, Section 481110 Section C	
21	Project Meetings: We currently have requirements in Section g for project meetings.	Section G, Sections 000110 and 013119	
22	have option to provide additional receivers if the design dictates their necessity. Previous correspondence with NPPD suggested that compressors, dryers and receivers would be provided for each unit, with a cross-tie. S&L feels this is unnessesary, involves extra equipment to operate and maintain, and will require the absorber buildings to be larger.	Section G, Sections 011100 and 431250	
23	V V	Section G, Attachment 2	
	Need to develop a complete equipment/component numbering guideline that is to be	Section G, Attachment 6	
		Section H, paragraph A	At time of issuing contract
8		Section H, paragraph A	At time of issuing contract
		Section H, paragraph D	At time of issuing contract
B	, ,	Section I, paragraph B	At time of issuing contract
29	NPPD to advise on requirements for hard copies, if any	Section I, paragraph E.1.a	Three hard copies plus electronic
1	A semperature of the second se	0 " 1	PM 1 B 1/4 1

Section I, paragraph E.3.b

Section I, paragraph F

Bob Nitsch

At time of issuing contract

Project No. 12681-006

9/8/11